
## PAULY



Fotoelektrik Pauly GmbH & Co. KG, Wahrbrink 6, D-59368 Werne, Telefon 02389/40227-70, Telefax 02389/40227-77, www.pauly-lichtschranken.de

## Transmitter—Receiver Light Barrier Type PU2092/2 with 'intelligent' Pollution Warning Output



Anti heat shield & anti dust tubes (K)JT19

Hints: The bright—dark switching is standard. This switch is accessible by removing the blanking screw designated 'PG1'. Switching to bright means that the output circuit of the main contact element (here the pnp transistor) is operated when the light emitted from the transmitter reaches the receiver. The switching indicator — LED (green) — for the main contact element always lights up when the light path is free.

usually impair functioning

The turn—on (Ti) and turn—off delay (Ta) for the main contact element is available on request. The delay times are increased by adjusting in a clockwise direction the potentiometer located under the PG2 screwing. The adjustable time range lies between approx. 0 and approx. 10 seconds. Alternatively, the following delays are available on request: 1 sec., 3 sec. and 20 sec.

seconds. Alternatively, the following delays are available on request: 1 sec., 3 sec. and 20 sec.

Graph The level indicator "DIANA" (Digital ANaloge Anzeige — digital analog indicator) is also optional.

DIANA indicates approximately 20—fold to 25—fold levels above the response threshold. It is not necessary for all DIANA LEDs to light up in order for the light barrier to function perfectly!

Switching the optional test input to 0V will interrupt the transmitter

The switching equipment for the pollution warning (VK vellow LED):

When. subsequent to as it.

The switching equipment for the pollution warning (VK, yellow LED) is switched through when, subsequent to an interruption in light beam (red LED on) and the light path being free again (green LED on), dirt or clogging causes the signal level to be under five times the minimum level (red and green LEDs on) and the light beam is then interrupted again. At this point in time, the light barrier is still fully functional. As soon as the dirt has been removed (green LED on, red LED off), the dirt indicator (yellow LED) switches off.

\*E\_1722 1.TXT\*

ssible by removing the e output circuit of the legight emitted from the ) – for the main contact the potentiometer located approx. 0 and approx. 10 circuit of sec., 3 sec. and 20 sec. indicator) is also optional. Is sponse threshold. It is not function perfectly! itter ED) is switched through dithe light path being free

17.02.05 mj

Diafragms

Optical Filters

Adjusting flange JF19H (1)

Cooling water flange KW19

Elbow tube adjustment JR19(2&3)

The design and make of the devices and their electronics are intellectual property of the company "Fotoelektrik Pauly GmbH & Co. KG". Internal circuit diagrams can, for copyright reasons, not be given therefore. Subject to technical alterations. Errors excepted. The reprinting of this data sheet or the copying of extracts from it are allowed only with the approval of the "Fotoelektrik Pauly GmbH & Co. KG" and with an indication of the sources used. Infringements are punishable by law.